

**ANTICIPATED ENERGY PERFORMANCE**

Scenario	Annual Energy Costs			MNECB Performance		LEED Canada & Environmental Performance		
	Electricity Cost	Natural Gas Cost	Total Energy Cost	% Energy Savings to MNECB	\$ Energy Savings to MNECB	Energy Cost Savings % (See Note 1)	LEED EAc1 Points (max 10)	GHG Savings tonnes CO <sub>2</sub> /yr (See Note 2)
MNECB Reference Building	\$ 13,807	\$ 933	\$ 14,740	-	-	-	-	-
Proposed Design	\$ 4,259	\$ 909	\$ 5,168	62.8%	\$ 9,572	67.1%	10	23.4

- 1. Excludes receptacle & fixed energy costs.
- 2. Greenhouse gas savings based on Ontario fuel mix.

